

TX1840027

Annual Drinking Water Quality Report

CITY OF WILLOW PARK

For more information regarding this report contact:

Annual Water Quality Report for the period of January 1 to December 31, 2012

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Name Lance Petty

Phone 817-441-7108

CITY OF WILLOW PARK is Ground Water

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono () - -.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Public Participation Opportunities

Date: 2nd Tuesday of the month

Time: 7:00 P.M.

Location: 516 Ranch house Rd., Willow Park Tx. 76087

Phone Number: 817-441-7108

To learn about future public meetings (concerning your drinking water), or to schedule one, please call us.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
<http://gis3.teeq.state.tx.us/swaw/Controller/index.jsp?wtsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.teeq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 - INDIAN CAMP / LAKE VIEW	GW	A	Paluxy
10P - SURREY LN	GW	A	Paluxy
11 - SQUAW CREEK RD	GW	A	Paluxy
12 - SW OF SHERWOOD CIR / WILLOW	GW	A	Paluxy
13 - ROYAL VIEW DR / WILLOW WOOD S	GW	A	Paluxy
14 - INDIAN CAMP / CROWN RD	GW	A	Paluxy
15 - INDIAN CAMP / CROWN RD	GW	A	TRINITY
16P - 1109 FOX HUNT TRL	GW	A	Paluxy
16T - 1109 FOX HUNT TRL	GW	A	Trinity
17 - PS 1 (WILLOW SPRINGS S / QUAIL	GW	A	Paluxy
18 - PS 1 (WILLOW SPRING N / QUAIL	GW	A	Paluxy
2 - E LAKE DR	GW	A	Paluxy
20 - PS 2 (WILLOW SPRINGS / OAKS	GW	A	Paluxy
3 - E LAKE DR	GW	A	Paluxy
4 - E LAKE DR	GW	A	Paluxy
5 - INDIAN CAMP	GW	A	Paluxy
6P - RIDGE RD	GW	A	Paluxy

6T - RIDGE RD
EL CHICO

RIDGE RD

GW
GW

A
A

Trinity
Paluxy

2012 Regulated Contaminants Detected

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1		0	N	Naturally present in the environment.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL: million fibers per liter (a measure of asbestos)

na: not applicable.

NTU: nephelometric turbidity units (a measure of turbidity)

PCi/L: picocuries per liter (a measure of radioactivity)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppt: parts per trillion, or nanograms per liter (ng/L)

ppq: parts per quadrillion, or picograms per liter (pg/L)

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Halobenzoic Acids (HAA5)*	05/24/2010	8.3	8.3 - 8.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trichloromethanes (TTHM)	05/24/2010	17.9	17.9 - 17.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	12/27/2011	0.119	0.119 - 0.119	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	12/27/2011	5.37	5.37 - 5.37	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2012	0.24	0.24 - 0.24	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2012	0.34	0.23 - 0.34	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	12/27/2011	2.6	2.6 - 2.6	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Thallium	12/27/2011	0.178	0.178 - 0.178	0.5	2	ppb	N	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2012	1	1 - 1	0	5	pCi/L	N	Erosion of natural deposits.

Violations Table

E. coli			
Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	06/01/2011	2012	We failed to collect follow-up samples within 24 hours of learning of the total coliform-positive sample. These needed to be tested for fecal indicators from all sources that were being used at the time the positive sample was collected.

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	08/02/2008	10/03/2012	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.
PUBLIC NOTICE RULE LINKED TO VIOLATION	10/16/2009	10/03/2012	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.
PUBLIC NOTICE RULE LINKED TO VIOLATION	03/01/2010	10/03/2012	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

Source Water Assessment

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Lance Petty 817-441-7108

Source Water Treatment

The City of Willow Park disinfects your source water using chlorine (gas).

1. The average level of quarterly levels are 2.1 residual
2. The lowest result of a single sample is .22
3. The highest result of a single sample recording 3.8
4. The maximum residual disinfectant level -- 3.8
5. Maximum residual disinfectant level goal – 2.0
6. The unit of measure – mg/l cl₂
7. Source of chemical - gas